

11939 Nassau Andree, Applicant

STATUTE/RULE CITATION:

381.0065(4)(a), FS - Lot is not 1/2 acre (0.48 acre requested, 0.5 acre required)

RECOMMENDATIONS:

Approved

Variance Committee: A (SHO-Y CHD-Y DEP-Y STI-1 HBI-2 REI-Y ENG-Y)

Health Officer: A

11940 Charlotte Metzger, Applicant

STATUTE/RULE CITATION:

64E-6.001(4)(a)3., FAC - Reuse drainfield <12" above SHWT (current df standards requested, existing drainfield required)

RECOMMENDATIONS:

Failure to satisfy the department that:

The drainfield currently sits in the water table during the wet season and during times when the water table is high.

At those times, the present system discharges sewage effluent directly into the groundwater.

This variance proposal would significantly degrade the groundwater.

It is not unreasonable to require you to modify the onsite system to meet the minimum standards for sewage treatment under Florida Administrative Code.

Variance Committee: D (SHO-1 CHD-Y DEP-Y STI-2 HBI-Y REI-Y ENG-Y)

Health Officer: D

11941 Orange Hash, Applicant Hurst, Agent

STATUTE/RULE CITATION:

64E-6.005(2),FAC - Setback to building (0.5 ft requested, 5 ft required)

64E-6.005(2), FAC - Setback to property line (0.5 ft requested, 5 ft required)

RECOMMENDATIONS:

Approved

Variance Committee: A (SHO-2 CHD-1 DEP-Y STI-Y HBI-Y REI-Y ENG-Y)

Health Officer: A